



# Velociti® Series AOM-2SF Technical Specifications

## SYSTEM

**Supervisory Current:** 0.00375 amps

**Alarm Current:** .0065 amps

**Operating Temperature:** 32° to 120° F (0° to 49° C)

**Relative Humidity:** 10 to 93% relative humidity (non-condensing)

**Dimensions:** 4 1/2" H x 4" W x 1 1/4" D  
(11.4 H x 10.2 W x 3.2 D cm)

## TEMPERATURE AND HUMIDITY RANGES

This system meets NFPA requirements for operation at 0 – 49°C/32 – 120°F and at a relative humidity 93% ± 2% RH (noncondensing) at 32°C ± 2°C (90°F ± 3°F).

However, the useful life of the system's standby batteries and the electronic components may be adversely affected by extreme temperature ranges and humidity. Therefore, it is recommended that this system and its peripherals be installed in an environment with a normal room temperature of 15 – 27°C/60 – 80°F.

## STANDARDS

The Velociti Series AOM-2SF are designed to comply with the following standard:

**UL Standards:** UL 864 9th Edition

## AGENCY LISTINGS AND APPROVALS

These listings and approvals apply to the modules specified in this document. In some cases, certain modules or applications may not be listed by certain approval agencies, or listing may be in process. Consult factory for latest listing status.

**UL:** S1949

**FM:** 3023594

**MEA FDNY:** 227-03-E Vol. IV

**CSFM:** 7300-1703:0102

**ISO 9001 Certification**

For a complete listing of all compliance approvals and certifications, please visit:

<http://www.gamewell-fci.com/en-US/documentation/Pages/Listings.aspx>

Velociti® and Gamewell-FCI® are registered trademarks of Honeywell International Inc.

UL® is a registered trademark of Underwriters Laboratories Inc.

This document is not intended to be used for installation purposes. We try to keep our product information up-to-date and accurate. We cannot cover all specific applications or anticipate all requirements. All specifications are subject to change without notice.

## For more information

Learn more about Gamewell-FCI's Velociti® Series AOM-2SF and other products available by visiting [www.Gamewell-FCI.com](http://www.Gamewell-FCI.com)

## Honeywell Gamewell-FCI

12 Clintonville Road  
Northford, CT 06472-1610  
203.484.7161  
[www.honeywell.com](http://www.honeywell.com)

9020-0627 | | 08/18  
©2018 Honeywell International Inc.

**Honeywell**