

# XP95A Heat Detector



### **Product overview**

Product	XP95A Heat Detector	
Part No.	SA5500-450	
Digital Communication	XP95 protocol	

# **Approvals**



### **Product information**

The XP95A Heat Detector monitors temperature by using a single thermistor which provides a voltage output proportional to the external air temperature. It is classified as an ordinary detector by UL.

- Compatible with all devices from the latest UL268 7th Edition approved XP95A range
- Electronic temperature sensing
- Alarm flag for fast alarm responding
- Automatic addressing with the XPERT 7 card
- Electronic free 4" or 6" bases
- Easy installation
- · Elegant design
- Ideal for environments that are dirty or smoky under normal circumstances
- Well suited for warehouses, loading docks and parking areas

### Technical data



CAUTION: System compatibility
The XP95A Heat Detector, Part No. SA5500-450 can
only be used on existing systems operating with XP95
protocol.

This detector is a direct replacement for the 55000-450 XP95A Heat Detector.

All data is supplied subject to change without notice. Specifications are typical at 24 V, 73°F and 50% RH unless otherwise stated.

Sensor Single NTC thermistor

Sampling frequency

Digital communication

Supply voltage

One second

XP95

17 - 28 V dc

Modulation Voltage at 5 V to 9 V peak to peak

Detector

 Supervisory current
 250 μA

 Surge current
 1 mA

 Alarm current
 3 mA max

 Operating temperature range
 32 °F to 151°F

Humidity 0% to 95% RH (no condensation or

icing)

Standards and approvals UL, FM

**Dimensions** 3.93" diameter x 1.65" height

Weight 3.70 oz

Materials Housing: White flame-retardant

polycarbonate

Terminals: Tin plated stainless

steel

Test method Hair dryer

Spacing

Smooth ceiling 60 ft to wall or partition 25 ft

36 Brookside Road, Havant Hampshire, PO9 1JR, UK.

Tel: +44 (0)23 9249 2412 | Fax: +44 (0)23 9249 2754 |

Email: sales@apollo-fire.com Web: www.apollo-fire.co.uk All information in this document is given in good faith but Apollo Fire Detectors Ltd cannot be held responsible for any omissions or errors. The company reserves the right to change the specifications of products at any time and without prior notice.













### Operation

The XP95A Heat Detector has a common profile with the ionisation and optical smoke detectors but has a low air flow resistance case made of white polycarbonate.

The device monitors heat using a single thermistor network which provides a voltage output proportional to the external air temperature.

# **Electrical description**


The XP95A Heat Detector is designed to be connected to a two wire loop circuit carrying both data and a 17 V to 28V dc supply. The detector is connected to the incoming and outgoing supply via terminals L1 and L2 in the mounting base. A remote LED indicator requiring not more than 1 mA may be connected between the +R and L2 terminals. An earth connection terminal is also provided. The detector is calibrated to give an analogue value of  $25\pm5$  counts at  $70^{\circ}F$ . This value increases with rising temperature. A count of 55 corresponds to the UL alarm sensitivity level of  $135^{\circ}F$ .

When the detector is energized the ASIC regulates the flow of power and controls the data processing. The thermistor provides an output over normal operating ranges that is proportional to the external air temperature. The voltage output is processed in the analogue to digital converter and stored by the communications ASIC. It is transmitted to the control equipment when the device is interrogated. When a count of 55 is exceeded the alarm flag is initiated and the device address is added to the data stream every 32 polling cycles from its last polling for the duration of the alarm level condition, except when an alarming device is being interrogated. This can provide a location identified alarm from any device on the loop in approximately two seconds.

## **Environmental characteristics**

The XP95A Heat Detector range is unaffected by wind or atmospheric pressure. Standard detectors are rated at 200  $^{\circ}\text{F}.$ 

# XP95A Heat Detector diagram



Response characteristics of XP95A Heat Detector			
Type of fire	Heat Detector		
OverHeating/Heat combustion	Very poor		
Smouldering/glowing combustion	Very poor		
Flaming combustion	Poor		
Flaming with high Heat output	Moderate/Good		
Flaming - clean burning	Moderate/Good		

Part Number	Product Name
SA5000-210	Soteria UL Base - 4"
SA5000-230	Soteria UL Base – 6"
SA5300-800	Soteria UL CO Sounder Base - 6" High Frequency
SA5300-802	Soteria UL Sounder Base - 6" High Frequency
SA5300-805	Soteria UL CO Sounder Base - 6" Low Frequency
SA5300-806	Soteria UL Sounder Base – 6" Low Frequency

	Smoke	Multi-Criteria	Heat
For existing XP95A installations choose:	SA5050-250 XP95A Smoke Detector	SA5050-350 XP95A Multi- Criteria Detector (Smoke/Heat)	SA5500-450 XP95A Heat Detector

This datasheet is to be used for marketing purposes only. All information on this datasheet is subject to change without notice. Technical information about installation can be found in the product installation guide which can be found on our website.

