



TECHNICAL DATA

MODEL VXD DOUBLE INTERLOCKED PREACTION SYSTEM WITH ELECTRIC/PNEU-LECTRIC RELEASE

The Viking Corporation, 210 N Industrial Park Drive, Hastings MI 49058
 Telephone: 269-945-9501 Technical Services: 877-384-5464 Fax: 269-818-1680 Email: techsvcs@vikingcorp.com
 Visit the Viking website for the latest edition of this technical data page www.vikinggroupinc.com

1. INTRODUCTION

Viking VXD Electric/Pneu-Letric Double Interlocked Preaction Systems utilize a Viking deluge valve, pneumatic supervision of the automatic sprinkler system, and an electric detection system. The deluge valve release trim utilizes a normally closed electric solenoid valve controlled by an approved release control panel with two initiating circuits configured for "cross-zoned" operation. One initiating circuit is connected to the electric detection system; the other to a "low-air" supervisory switch.

BOTH the electric detection system must activate AND supervisory air pressure must be relieved from the sprinkler system before the deluge valve will open to fill the sprinkler system with water. If the electric detection system (alone) operates, an alarm will activate but the deluge valve will NOT open. If the sprinkler piping is damaged or a sprinkler is broken or fused, but the detection system has not activated, an alarm will activate, but the deluge valve will NOT open.

In fire conditions, after both the detection system and a sprinkler operate, the deluge valve opens, allowing water to enter the system.

Electric/pneu-lectric double interlocked preaction systems are commonly used as refrigerated area systems. They are also commonly used where flooding of the sprinkler system piping can have serious consequences and where it is important to control accidental water discharge due to damaged sprinkler piping.



2. LISTINGS AND APPROVALS

cULus Listed - Categories VLFT and VLFT7

FM Approved - Viking Electric/Pneu-Letric Double-Interlocked Preaction Systems are Factory Mutual (FM) Approved as refrigerated area systems.

3. ORDERING INFORMATION

NOTE: Loose trim packages do NOT include deluge valve, coupling, or riser check valve. These items must be purchased separately. Refer to the applicable technical data sheets for available options.

Table 1: Available Sizes for Model VXD Double-Interlock Preaction System with Electric Pneu-Letric Release (Vertical)

Nominal Size	Part Number		
	Loose trim Galvanized	Loose trim Brass	Pre-trimmed ¹ Galvanized
1-½	23562-1	23562-2	23563
2	23583-1	23583-2	23584
2½	23604-1	23604-2	23605
3	23625-1	23625-2	23626
4	23646-1	23646-2	23647
6	23668-1	23668-2	23669
8	23689-1	23689-2	23690
10	23750-1	23750-2	23751

1. Pre-trimmed packages are only available with galvanized pipe and groove/groove valves.



WARNING: Cancer and Reproductive Harm-
www.P65Warnings.ca.gov

Table 2: Additional System Component Information

Component	Scan, click or tap
Pressure Operated Relief Valve (PORV)	
Solenoid Valve	



TECHNICAL DATA

MODEL VXD DOUBLE INTERLOCKED PREACTION SYSTEM WITH ELECTRIC/PNEU-ELECTRIC RELEASE

The Viking Corporation, 210 N Industrial Park Drive, Hastings MI 49058
 Telephone: 269-945-9501 Technical Services: 877-384-5464 Fax: 269-818-1680 Email: techsvcs@vikingcorp.com
 Visit the Viking website for the latest edition of this technical data page www.vikinggroupinc.com

4. SYSTEM COMPONENTS




Figure 1: System Components (4" Shown)

Item	Description	Item	Description	Item	Description
A	Deluge valve	I	Emergency release valve (normally closed)	1	Water flow alarm (example: PS-10) connection point (device purchased separately)
B	Solenoid valve	J	Water supply pressure gauge	2	Drain connection point (piping not provided)
C	Drain cup	K	Flow test valve (normally closed)	3	Prime supply connection point (must be piped to upstream of main water supply valve; piping not provided)
D	In-line check valve	L	Pressure Operated Relief Valve (P.O.R.V.)	4	Air supply or Low Air switch (example: PS-40) connection point (devices purchased separately)
E	1/8" Restricted orifice	M	Swing check valve		
F	Y-strainer	N	1/8" Restricted orifice		
G	Priming valve (normally open)	O	Alarm test valve (normally closed)		
H	Prime pressure gauge	P	Riser check valve (with drain trim)		

NOTE: Piping shown for reference only.



TECHNICAL DATA

MODEL VXD DOUBLE INTERLOCKED
PREACTION SYSTEM WITH
ELECTRIC/PNEU-ELECTRIC RELEASE

The Viking Corporation, 210 N Industrial Park Drive, Hastings MI 49058
Telephone: 269-945-9501 Technical Services: 877-384-5464 Fax: 269-818-1680 Email: techsvcs@vikingcorp.com
Visit the Viking website for the latest edition of this technical data page www.vikinggroupinc.com

5. SYSTEM OPERATION

5.1 In the SET condition:

In the SET condition: System water supply pressure enters the priming chamber of the deluge valve through the priming line, which includes a normally open priming valve (A), strainer (B), restricted orifice (not shown), and check valve (C). In the SET condition, water supply pressure is trapped in the priming chamber by the check valve (C) and the normally closed solenoid valve (E). The water supply pressure trapped in the priming chamber holds the deluge valve diaphragm closed, keeping the outlet chamber and system piping dry.




Figure 2: Operational Components



TECHNICAL DATA

MODEL VXD DOUBLE INTERLOCKED PREACTION SYSTEM WITH ELECTRIC/PNEU-ELECTRIC RELEASE

The Viking Corporation, 210 N Industrial Park Drive, Hastings MI 49058
 Telephone: 269-945-9501 Technical Services: 877-384-5464 Fax: 269-818-1680 Email: techsvcs@vikingcorp.com
 Visit the Viking website for the latest edition of this technical data page www.vikinggroupinc.com

5.2 In fire conditions:

In a fire condition:

1. Operation of the detection system activates the first initiating circuit in the control panel, causing an alarm to activate.
2. When a sprinkler operates, air pressure escapes from the sprinkler piping. The air supervisory switch (H) activates the second initiating circuit in system release control panel.
3. When BOTH initiating circuits have been activated, the system release control panel energizes the solenoid valve (E) open.

Pressure is released from the priming chamber to the open drain cup faster than it is supplied through the restricted orifice. The deluge valve diaphragm opens to allow water to flow into the system piping and alarm devices, causing the water motor alarm and water flow alarms connected to the alarm pressure switch to activate. When the deluge valve operates, water is drained from the PORV inlet. When the 10:1 differential is overcome, the push rod opens, allowing the prime water to drain. If a release resets, priming water will continue to escape through the PORV, allowing the deluge valve to continue to operate until the system is reset. The Deluge Valve can only be reset after the system is taken out of service, and the outlet chamber of the deluge valve and associated trim piping are depressurized and drained.




Figure 3: Fire Conditions



TECHNICAL DATA

**MODEL VXD DOUBLE INTERLOCKED
PREACTION SYSTEM WITH
ELECTRIC/PNEU-ELECTRIC RELEASE**

The Viking Corporation, 210 N Industrial Park Drive, Hastings MI 49058
Telephone: 269-945-9501 Technical Services: 877-384-5464 Fax: 269-818-1680 Email: techsvcs@vikingcorp.com
Visit the Viking website for the latest edition of this technical data page www.vikinggroupinc.com

5.3 In trouble conditions:

If a sprinkler opens prior to operation of a release device, or any time supervisory pressure in the sprinkler piping is lost, alarms connected to the air supervisory switch will signal a low air pressure condition, but the deluge valve will NOT open. If the electric detection system (alone) operates due to damage or malfunction, alarms connected to the system release control panel will activate, but the deluge valve will NOT open.

5.4 Manual operation:

Anytime the emergency release is pulled, pressure is released from the priming chamber and the deluge valve will open. Water will flow into the system piping and alarm devices. Water will flow from any open sprinklers and/or spray nozzles on the system.

6. INSTALLATION

Refer to current Viking Technical Data describing individual components of the Viking VXD Deluge System. Also, refer to applicable installation standards, codes, and Authorities Having Jurisdiction.

6.1 Recommended Air Pressure Settings

NOTE: Installation Standards may allow supervisory pressures lower than those recommended in this document. When using supervisory pressures lower than the recommended setting noted above, verify that the air regulation equipment and air supervisory switches used are compatible with the supervisory pressure setting used.

TABLE 1: Recommended Air Pressure Settings		
Device	Recommended Pneumatic Supervisory Pressures and Settings	
	For Supervisory Pressure of 30 PSI (2 bar), set to maintain	For Supervisory Pressure of 10 PSI (0.7 bar), set to maintain
Air Compressor On/Off Switch	ON: 30 PSI (2.1 bar) OFF: 40 PSI (2.8 bar)	ON: 12.5 PSI (0.9 bar) Minimum OFF: 22.5 PSI (1.5 bar)
Air Maintenance Device	30 PSI (2 bar)	10 PSI (0.7 bar)
Low-air alarm contact setting on release system pressure supervisory switch	25 PSI (1.7 bar) on pressure drop	7.5 PSI (0.52 bar) on pressure drop
Setting for contacts on release system pressure supervisory switch to activate release control panel initiating circuit	20 PSI (1.4 bar) on pressure drop	5 PSI (0.34 bar) on pressure drop
Alarm pressure switch	4 to 8 PSI (0.3 to 0.6 bar)	4 to 8 PSI (0.3 to 0.6 bar)

6.2 Air Supply Design

The air supply compressor should be sized to establish total required air pressure in 30 minutes. The air supply must be regulated, restricted, and maintained automatically. The air maintenance device is used to regulate and restrict the flow of supervisory air into the sprinkler system piping.

The air supply must be regulated to maintain the pressure desired in the release system. Pressure settings other than those recommended in section 6.1 above may affect operation of the system. The air supply must be restricted to ensure that the automatic air supply cannot replace air as fast as it escapes when a releasing device operates. It is recommended practice to provide an inspector's test connection on the supervised sprinkler piping.

For systems in excess of 750 gal (2840 L), a trip test connection must be installed per NFPA 13 on the end of the most distant sprinkler pipe in the upper story, equipped with a readily accessible shutoff valve and plug not less than 1" (25 mm), at least one of which shall be brass. The trip test connection shall be not less than 1" (25 mm) in diameter, terminating in a smooth bore corrosion-resistant orifice to provide a flow equivalent to one sprinkler of a type installed on the system.

Riser Mounted Air Compressors:

A riser mounted air compressor may be suitable for small electrically operated double-interlocked preaction systems; however, placement of a dehydrator and/or an air maintenance device in the outlet piping of a riser mounted air compressor may affect operation of the compressor.

1. When a dehydrator is not installed, verify that the installation is located in a dry environment (not humid) and that the supervised sprinkler piping is never subject to freezing.
2. When an air maintenance device is not used, verify that the air supply produced is properly "regulated" and "restricted". See Air Supply Design paragraphs above, and section 9. INSPECTIONS, TESTS AND MAINTENANCE.

Speed of Operation:

An optional accelerator may be installed to allow the system to fill with water faster. An accelerator may be necessary to meet water delivery time requirements.



TECHNICAL DATA

MODEL VXD DOUBLE INTERLOCKED
PREACTION SYSTEM WITH
ELECTRIC/PNEU-ELECTRIC RELEASE

The Viking Corporation, 210 N Industrial Park Drive, Hastings MI 49058
Telephone: 269-945-9501 Technical Services: 877-384-5464 Fax: 269-818-1680 Email: techsvcs@vikingcorp.com
Visit the Viking website for the latest edition of this technical data page www.vikinggroupinc.com

7. PLACING THE SYSTEM IN SERVICE

Placing the Valve in Service:

1. Verify the following:
 - The system main water supply control valve (not shown) is closed.
 - The system has been properly drained and main drain (H) is open.
 - The emergency release (F) is closed.
2. Close the system main drain (H).

NOTE: For the next 2 steps, Refer to section "6. INSTALLATION".

3. Restore supervisory pressure to the sprinkler piping. Verify that the 1/2" valve in the air maintenance device by-pass trim is closed and that both the 1/4" valves are open.
4. Open the priming valve (A).
5. Open flow test valve (G).
6. Slowly and partially open main water supply control valve (not shown).
- NOTE: Opening the main water supply valve too quickly can create excessive pressure causing the valve to trip.**
7. When full flow develops from the flow test valve (G), close the valve. Verify that there is no flow from the open orifice.
8. Fully open and secure the main water supply control valve.
9. Verify that all valves are in their normal operating position.
10. Verify that no water is discharging into the drain cup.
11. Check for, and repair all leaks.
12. On new installations, those systems that have been placed out of service, or where new equipment has been installed, trip test the system to verify that all equipment functions properly. Refer to Annual Trip Tests, section 9.2.C.
13. After completing a trip test, perform semi-annual maintenance. Refer to section 9.3.B.

⚠ CAUTION

Performing a trip test results in operation of the Deluge Valve. Water will flow into the sprinkler piping. Take necessary precautions to prevent damage.

8. EMERGENCY INSTRUCTIONS

⚠ WARNING

WARNING: Placing a control valve or detection system out of service may eliminate the fire protection capabilities of the system. Prior to proceeding, notify all Authorities Having Jurisdiction (AHJ). Consideration should be given to employment of a fire patrol in the affected areas.

Refer to the appropriate technical data page and NFPA standards for complete care, handling, installation, and maintenance instructions. For additional product and system information, Viking data pages and installation instructions are available on the Viking Web site at www.vikinggroupinc.com.




Figure 4: Placing the System in Service



TECHNICAL DATA

MODEL VXD DOUBLE INTERLOCKED
PREACTION SYSTEM WITH
ELECTRIC/PNEU-ELECTRIC RELEASE

The Viking Corporation, 210 N Industrial Park Drive, Hastings MI 49058
Telephone: 269-945-9501 Technical Services: 877-384-5464 Fax: 269-818-1680 Email: techsvcs@vikingcorp.com
Visit the Viking website for the latest edition of this technical data page www.vikinggroupinc.com

To take system out of service (Refer to Figure 4):

After a fire, verify that the fire is OUT and that placing the system out of service has been authorized by the appropriate Authority Having Jurisdiction.

1. Close the water supply control valve (not shown).

NOTE: Sprinkler systems that have been subjected to a fire must be returned to service as soon as possible. The entire system must be inspected for damage, and repaired or replaced as necessary.

2. Open the system main drain (H).
3. Shut off the air supply (optional).
4. Close the priming valve (A).
5. Replace any release devices, sprinklers and/or spray nozzles that have been damaged or have been exposed to fire conditions.
6. Perform all maintenance procedures recommended in Technical Data describing individual components of the system that have operated.
7. Return the system to service as soon as possible. Refer to section "7. PLACING THE SYSTEM IN SERVICE".

9. INSPECTIONS, TESTS, AND MAINTENANCE

⚠ WARNING

Any system maintenance that involves placing a control valve or detection system out of service may eliminate the fire protection capabilities of that system. Prior to proceeding, notify all Authorities Having Jurisdiction. Consideration should be given to employment of a fire patrol in the affected areas.

NOTICE

The owner is responsible for maintaining the fire protection system and devices in proper operating condition.

It is imperative that the system be inspected and tested on a regular basis in accordance with NFPA 25. Refer to current Viking Technical Data describing individual components.

The frequency of the inspections may vary due to contaminated water supplies, corrosive water supplies, corrosive atmospheres, as well as the condition of the air supply to the system. For minimum maintenance and inspection requirements, refer to NFPA 25. In addition, the Authority Having Jurisdiction may have additional maintenance, testing, and inspection requirements that must be followed.

9.1 Inspection

Weekly - Viking recommends a weekly visual inspection; check the following items.

- Verify that the main water supply control valve is open and that all other valves are in their normal operating position and appropriately secured. (refer to Figure 4)
- Check for signs of mechanical damage, leakage, and/or corrosive activity. If detected, perform maintenance as required. If necessary, replace the device.
- Verify that the valve and trim are adequately heated and protected from freezing and physical damage.

NOTE: For normal operating position, refer to Figure 1.

9.2 Periodic System Tests

A. Quarterly Water Flow Alarm Test

1. Notify the Authority Having Jurisdiction and those in the area affected by the test.
2. To test the local electric alarm (if provided) and/or mechanical water motor alarm (if provided), OPEN the alarm test valve in the Deluge Valve trim.
 - a. Electric alarm pressure switches (if provided) should activate.
 - b. Electric local alarms should be audible.
 - c. The local water motor gong should be audible.
 - d. If equipped with remote station alarm signaling devices, verify that alarm signals were received.
3. When testing is complete, CLOSE the Alarm Test Valve.



TECHNICAL DATA

**MODEL VXD DOUBLE INTERLOCKED
PREACTION SYSTEM WITH
ELECTRIC/PNEU-ELECTRIC RELEASE**

The Viking Corporation, 210 N Industrial Park Drive, Hastings MI 49058
Telephone: 269-945-9501 Technical Services: 877-384-5464 Fax: 269-818-1680 Email: techsvcs@vikingcorp.com
Visit the Viking website for the latest edition of this technical data page www.vikinggroupinc.com

4. Verify the following:
 - a. All local alarms stop sounding and alarm panels (if provided) reset.
 - b. All remote station alarms reset.
 - c. Supply piping to water motor alarm properly drains.
5. Verify that the Alarm Test Valve is CLOSED.
6. Verify that the outlet chamber is free of water. No water should flow from the alarm drain line.
7. Notify the Authority Having Jurisdiction and those in the affected area that testing is complete.

B. Quarterly Main Drain Test

1. Notify the Authority Having Jurisdiction and those in the area affected by the test.
2. Record pressure reading from the water supply pressure gauge.
3. Verify that the outlet chamber of the Deluge Valve is free of water. No water should flow from the alarm drain line.
4. Fully OPEN the Flow Test Valve.
5. When a full flow is developed from the Flow Test Valve, record the residual pressure from the water supply pressure gauge.
6. When the test is complete, SLOWLY CLOSE the Flow Test Valve.
7. Compare test results with previous flow information. If deterioration of the water supply is detected, take appropriate steps to restore adequate water supply.
8. Verify:
 - a. Normal water supply pressure has been restored to the inlet chamber, the priming chamber, and the release system. The pressure on the priming chamber water pressure gauge should equal the system water supply pressure.
 - b. All alarm devices and valves are secured in normal operating position (refer to Figure 1).
9. Notify the Authority Having Jurisdiction that the test is complete. Record and/or provide notification of test results as required by the Authority Having Jurisdiction.

C. Annual Trip Test

⚠ CAUTION

Performing this test results in operation of the Deluge Valve. Water will flow into the sprinkler piping and from any open sprinklers and/or nozzles. Take necessary precautions to prevent damage.

1. Notify the Authority Having Jurisdiction and those in the area affected by the test.
2. Fully open the Flow Test Valve to flush away any accumulation of foreign material.
3. Close the Flow Test Valve.
4. Trip the system by operating the release system and opening the inspectors test connection. Allow a full flow to pass through the Deluge Valve. Water flow alarms should operate.
5. When test is complete:
 - a. Close the Main Water Supply Control Valve.
 - b. Close the Priming Valve.
 - c. Open all system main drains. Allow the system to drain completely.
6. Perform semi-annual maintenance. Refer to section: 9.3.B: Semi-Annual Maintenance.
7. Place the system in service. Refer to section: "7. PLACING THE SYSTEM IN SERVICE".
8. Notify the Authority Having Jurisdiction that the test is complete. Record and/or provide notification of test results as required by the Authority Having Jurisdiction.

D. Quarterly "Low Air" Pressure Alarm Test

IMPORTANT

Do not operate the electric detection system during this test.

1. Notify the Authority Having Jurisdiction and those in the area affected by the test.
2. Close the main water supply valve.
3. Fully OPEN the test connection to simulate operation of a sprinkler.



TECHNICAL DATA

**MODEL VXD DOUBLE INTERLOCKED
PREACTION SYSTEM WITH
ELECTRIC/PNEU-ELECTRIC RELEASE**

The Viking Corporation, 210 N Industrial Park Drive, Hastings MI 49058
 Telephone: 269-945-9501 Technical Services: 877-384-5464 Fax: 269-818-1680 Email: techsvcs@vikingcorp.com
 Visit the Viking website for the latest edition of this technical data page www.vikinggroupinc.com

4. Verify that the low air alarms operate within an acceptable time period and continue without interruption.
5. Close the test connection.
6. Establish recommended pneumatic supervisory pressure to be maintained. Refer to section "6.1 Important Settings".
7. Reset the system release control panel to stop the alarms.
8. Return the system to service. Refer to section: "7. PLACING THE SYSTEM IN SERVICE".

9.3 Maintenance

A. After Each Operation:

1. Sprinkler systems that have been subjected to a fire must be returned to service as soon as possible. The entire system must be inspected for damage, and repaired or replaced as necessary.
2. Deluge Valves and trim that have been subjected to brackish water, salt water, foam/water solution, or any other corrosive water supply, should be flushed with good quality fresh water before being returned to service.
3. Perform semi-annual maintenance after every operation.

B. Semi-Annually:

1. Remove the system from service.
2. Close the Main Water Supply Control Valve and Priming Valve.
3. Relieve pressure in the priming chamber by opening the emergency release Valve.
4. Inspect all trim for signs of corrosion and/or blockage. Clean and/or replace as required.
5. Clean and/or replace all strainer screens.
6. Refer to section: "7. PLACING THE SYSTEM IN SERVICE".

C. Every Fifth Year:

1. Internal inspection of Deluge Valves is recommended every five years unless inspections and tests indicate more frequent internal inspections are required. Refer to the Model VXD Valve Technical Data Page.
2. Internal inspection of strainers, and restricted orifices is recommended every five years unless inspections and tests indicate more frequent internal inspections are required.
3. Record and provide notification of inspection results as required by the Authority Having Jurisdiction.



TECHNICAL DATA

**MODEL VXD DOUBLE INTERLOCKED
PREACTION SYSTEM WITH
ELECTRIC/PNEU-ELECTRIC RELEASE**

The Viking Corporation, 210 N Industrial Park Drive, Hastings MI 49058
Telephone: 269-945-9501 Technical Services: 877-384-5464 Fax: 269-818-1680 Email: techsvcs@vikingcorp.com
Visit the Viking website for the latest edition of this technical data page www.vikinggroupinc.com

10. DIMENSIONS




Figure 5: Dimensions - 1-1/2"

*Not to scale.
All dimensions are approximate.*




Figure 6: Dimensions - 2"

*Not to scale.
All dimensions are approximate.*



TECHNICAL DATA

**MODEL VXD DOUBLE INTERLOCKED
PREACTION SYSTEM WITH
ELECTRIC/PNEU-ELECTRIC RELEASE**

The Viking Corporation, 210 N Industrial Park Drive, Hastings MI 49058
Telephone: 269-945-9501 Technical Services: 877-384-5464 Fax: 269-818-1680 Email: techsvcs@vikingcorp.com
Visit the Viking website for the latest edition of this technical data page www.vikinggroupinc.com




Figure 7: Dimensions - 2 1/2"

*Not to scale.
All dimensions are approximate.*




Figure 8: Dimensions - 3"

*Not to scale.
All dimensions are approximate.*



TECHNICAL DATA

**MODEL VXD DOUBLE INTERLOCKED
PREACTION SYSTEM WITH
ELECTRIC/PNEU-ELECTRIC RELEASE**

The Viking Corporation, 210 N Industrial Park Drive, Hastings MI 49058
Telephone: 269-945-9501 Technical Services: 877-384-5464 Fax: 269-818-1680 Email: techsvcs@vikingcorp.com
Visit the Viking website for the latest edition of this technical data page www.vikinggroupinc.com




Figure 9: Dimensions - 4"

*Not to scale.
All dimensions are approximate.*




Figure 9: Dimensions - 6"

*Not to scale.
All dimensions are approximate.*



TECHNICAL DATA

**MODEL VXD DOUBLE INTERLOCKED
PREACTION SYSTEM WITH
ELECTRIC/PNEU-ELECTRIC RELEASE**

The Viking Corporation, 210 N Industrial Park Drive, Hastings MI 49058
Telephone: 269-945-9501 Technical Services: 877-384-5464 Fax: 269-818-1680 Email: techsvcs@vikingcorp.com
Visit the Viking website for the latest edition of this technical data page www.vikinggroupinc.com




Figure 10: Dimensions - 8"

*Not to scale.
All dimensions are approximate.*




Figure 11: Dimensions - 10"

*Not to scale.
All dimensions are approximate.*