

Kidde Fire Systems

Natura™ Inert Gas System

Component Description



Effective: April 2022
K-38-2455 Rev AE

Back-Plate Manifold Hoses

FEATURES

- For Approvals, see the “COMPATIBILITY” table.
- REACH and RoHS compliant

DESCRIPTION

Use the 27.6 in. (700mm) hose (P/N 01-3273-1200) to connect the back-plate manifold to the selector valves. The hose is also used to connect the manifold to the pressure regulator on the Back-Plate Manifold.

ORDERING INFORMATION

Part Number	Description
01-3273-1200	27.6 in. (700mm) Back-Plate Manifold Hose

COMPATIBILITY

Series	DIOM P/N	Approvals*
Natura™ Inert Gas System	06-237619-001	FM, UL
Natura™ Inert Gas System	06-237598-001	LPCB
* For additional listings, contact Kidde Fire Systems		

SPECIFICATIONS

Bursting Pressure: 1600 bar

Working Pressure: 400 bar

Bending Radius: Min 100 mm

Weight: 0.32 kg (0.7 lbs)

Hose Material: SBR and Nitrile Rubber, Oil Resistant with Reinforcement Wire. SAE 100 R2 DIN 20022

Coupling Material: Steel, Zinc Plated

O-ring Material: ø6.5 x ø1.0 NBR Shore 80 (P/N 15-0181-0005)

Temp Range(s):

FM Approved / UL Listed: -4° to 130°F (-20° to 54°C)*

*Unless superseded by local/national standards



Figure 1.




Figure 2.

EXPORT INFORMATION (USA)

Jurisdiction: EAR

Classification: EAR99

This document contains technical data subject to the EAR.

All trademarks are property of their respective owners.

©2022 Carrier

This literature is provided for informational purposes only. KIDDE-FENWAL, INC. believes this data to be accurate, but it is published and presented without any guarantee or warranty whatsoever. KIDDE-FENWAL, INC. assumes no responsibility for the product's suitability for a particular application. Product features specified are only applicable when the fire suppression system is correctly designed, installed, maintained and serviced by trained, authorized Kidde Fire Systems distributors as per the applicable design, installation, operation, and maintenance manuals. If you need more information on this product, or if you have a particular problem or question, contact: KIDDE-FENWAL, INC., Ashland, MA 01721 USA, Telephone: (508) 881-2000.

Kidde Fire Systems
400 Main Street
Ashland, MA 01721
Ph: 508.881.2000
Fax: 508.881.8920
kiddefiresystems.com