

Kidde Fire Systems Natura™ Inert Gas System Component Description



Effective: April 2021
K-38-2450 Rev AC

Back-Plate Manifold

FEATURES

- For Approvals, see the “COMPATIBILITY” table.
- REACH and RoHS compliant

DESCRIPTION

The back-plate manifold provides a pressure reduction valve so that manifold pressure can be used to operate selector valve solenoids.

SOLENOID SPECIFICATIONS

- **Operating Voltage:** 24 VDC
- **Current Draw:** 0.42 Amps

Note: Each solenoid requires a hose (P/N: 01-3273-1200) to connect the solenoid to its respective selector valve.



ORDERING INFORMATION

Part Number	Description
01-3508-0002	Back-Plate Manifold 2 Area, Selector/Divertor Valve Control, 8 Bar
01-3508-0003	Back-Plate Manifold 3 Area, Selector/Divertor Valve Control, 8 Bar
01-3508-0004	Back-Plate Manifold 4 Area, Selector/Divertor Valve Control, 8 Bar
01-3508-0005	Back-Plate Manifold 5 Area, Selector/Divertor Valve Control, 8 Bar

COMPATIBILITY

Series	DIOM P/N	Approvals*
Natura™ Inert Gas System	06-237619-001	FM, UL
Natura™ Inert Gas System	06-237598-001	LPCB
* For additional listings, contact Kidde Fire Systems		

EXPORT INFORMATION (USA)

Jurisdiction: EAR
Classification: EAR99
This document contains technical data subject to the EAR.

All trademarks are property of their respective owners.
©2021 Carrier

This literature is provided for informational purposes only. KIDDE-FENWAL, INC. believes this data to be accurate, but it is published and presented without any guarantee or warranty whatsoever. KIDDE-FENWAL, INC. assumes no responsibility for the product's suitability for a particular application. Product features specified are only applicable when the fire suppression system is correctly designed, installed, maintained and serviced by trained, authorized Kidde Fire Systems distributors as per the applicable design, installation, operation, and maintenance manuals. If you need more information on this product, or if you have a particular problem or question, contact: KIDDE-FENWAL, INC., Ashland, MA 01721 USA, Telephone: (508) 881-2000.

Kidde Fire Systems
400 Main Street
Ashland, MA 01721
Ph: 508.881.2000
Fax: 508.881.8920
kiddefiresystems.com