

Heater Box Installation Sheet




Fig. 1. Heater Box

- | | |
|--------------------|-----------------------|
| 1. Access plate | 4. Outlet to detector |
| 2. Air Inlets (x4) | 5. Cable gland |
| 3. Mounting lugs | |

- Inlets:- 4 x 3/4 inch male ABS tank connectors (25mm optional). If metal sampling pipe is to be used, these can be changed to the appropriate connectors.
- Outlets:- 2 x 3/4 inch male ABS tank connectors

Overview

The Stratos™ range of High Sensitivity Aspirating Smoke Detectors are suitable for installation within an area only if the ambient temperature is expected to be above 0°C (the minimum operating temperature of a Stratos™ detector is typically -10°C: check the specification of the particular detector in question). Where the air temperature in the protected area is consistently below this temperature, it is imperative that the detector is mounted outside the protected area, in an environment where the temperature meets that specified for the detector. However, the sampled air from the protected area must be conditioned before it is passed into the detector.

The Air Heater Box is designed to raise the temperature of the air drawn from a very cold environment by passing it across a heating element before it passes into the detector. In this manner, the problem of condensation on sampling pipework

external to the protected area is minimised. Warming the air sample will also ensure the components of the detector operate within the specified temperature tolerances, and it reduces the possibility of surface condensation.

Installation

Notes:

- The heater box must be used with any of the Stratos range of high sensitivity aspirating smoke detectors.
- Ensure the temperature of the selected location for the detector is within the specified limits (typically -10 to 60°C. Check the specification of the particular detector in question)
- The heater box should ideally be mounted approximately 900mm above the detector. To simplify interconnection, threaded socket unions should be used.

- Once the position of the heater box has been determined, access between the Heater Box sampling pipe inlets and the sampling pipes inside the protected area should be prepared. This penetration should be no more than 105 x 105mm. Care must be taken to restore any intumescent sealing, thermal insulation and air path sealing.
- If the mounting surface is corrugated or uneven, fix a suitable metal mounting plate.
- Offer the unit up to the opening and mark the position of the four fixing holes, using the mounting lugs as drill position guides.
- Connect ABS sampling pipes to the inlets, using joining sockets (when using sampling pipes in other materials, it may be necessary to fit stubs prior to fitting the heater box).
- Cap or plug and unused inlets and outlets, ensuring that an airtight seal is achieved.
- Fix the unit to the selected location with appropriate fasteners.
- Connect the Heater Box to a suitable electrical supply using insulated cable with a temperature rating of 105°C or better. Ensure that the individual wires are not under stress, and make sure that the cable is securely fixed in the cable gland with an airtight seal.
- The electrical supply should be from a 230V.AC unswitched spur fused at 3A.
- The heater box must be earthed.
- A conduit is required to protect the mains cable
- Mains power should be sourced directly from a separate circuit breaker in the building electrical supply distribution board. This circuit should be clearly marked, should have a bipolar disconnect device, and should only be used for fire detection equipment.

Installation procedure:

- Before proceeding with installation, those inlet and outlet ports not being used should be plugged using bungs provided. To simplify mechanical installation, a template has been provided on page 4 of this installation sheet.
- The cable entry for the supply is located at the base of the unit. The supply connection terminals. (see figure below) are accessed by removing the four posidrive-head screws on the front cover plate.




Fig. 2 Supply connection terminals

- The sampling pipe should enter the rear of the heater box using the appropriate number of inlet ports (four provided) immediately after exiting the cold area. The two pipes exiting the base of the heater box then enter the detector. To allow for the pipe work transition from the heater box to the detector, adequate space should be allowed for 2 x 45° bends per pipe as shown in figure 3.




Fig. 3 Typical installation format

Important: In order to avoid flow faults from being generated, the heater box should be switched on approximately 30 minutes before the detector, allowing the unit to pre-heat. The exhausted air may be moisture laden, upon re-entering the cold area condensation may form. Suitable precautions should be taken to ensure this condensate does not represent a safety hazard and / or does not obstruct the exhaust.

This network configuration is not recommended. It does not provide for redundancy in the transmission path and creates a fire network with high fault sensitivity.

Technical data

Supply voltage	230VAC (RMS)
Mains maximum current	1.1A
Mains average current	0.8A
Operating temperature range	-10 to +60°C
Operating humidity range	0 – 90% Non condensing
Mains cable requirements	3 x 1.5mm2
Bipolar disconnect device	5A

Limitation of liability

Installation in accordance with this manual, applicable codes, and the instructions of the authority having jurisdiction is mandatory. UTC Fire & Security (UTCFS) shall not under any circumstances be liable for any incidental or consequential damages arising from loss of property or other damages or losses owing to the failure of UTCFS products beyond the cost of repair or replacement of any defective products. UTCFS reserves the right to make product improvements and change product specifications at any time. While every precaution has been taken during the preparation of this manual to ensure the accuracy of its contents, UTCFS assumes no responsibility for errors or omissions.

Regulatory information

Placed in the market by:	Kidde Products Ltd, trading as Kidde AirSense, Thame Park Road, Thame, Oxfordshire, OX9 3RT
Produced in the factory by:	Kidde Products Ltd, trading as Kidde AirSense, UNIT 2, Dawson Business Park, Blair Way, Seaham, County Durham, SR7 7PP

Certification	 EN61010-1:2011
---------------	---



Hot surface



Ground

Fig. 4 Heater box template

